

**Addendum No.: Addendum No. 2**

Date: January 29, 2016

Project: Rio Rancho High School – Mechanical Upgrades  
301 LOMA COLORADO DR. NE,  
Rio Rancho, New Mexico 87124

ITB No: 2016-007-FAC

Project No.: 083006-15-002

From: Bridgers & Paxton Engineers  
4600C Montgomery Blvd NE  
Albuquerque, NM 87124

To: All Prospective Bidders and Plan Holders

This Addendum forms a part of the Contract Documents and modifies the Contract Documents issued by Bridgers & Paxton Engineers and dated **12/15/2015**. Acknowledge receipt of this Addendum on the Proposal Form. Failure to do so may subject the Offeror to disqualification. All other provisions of the Procurement Documents shall remain unchanged.

**1. CONTRACTOR QUESTIONS**

- 1.1. **QUESTION** – Are subcontractor bonds required for any amounts over 50,000 as per the invitation to bid, page 3? **ANSWER** – This amount shall be changed to \$125,000.
- 1.2. **QUESTION** – Who is responsible for moving the desks, furniture, computer equipment and personal items? **ANSWER** – District
- 1.3. **QUESTION** – It has been stated that the existing roof is not under warranty but there still are no specifications as to what the existing roof is composed of. When new premanufactured curbs are installed a roofer will still need to come and flash the curbs in to seal the roof. What is the material? Who is the manufacturer? **ANSWER** – Information not available at this time.
- 1.4. **QUESTION** – Was there any information regarding Panel MDP that is requiring a new breaker (EP-104 KN #5), Manufacturer/Type? **ANSWER** – Existing Panel MDP is manufactured by Siemens, 1600A, 65,000K AIC. Refer to attachment MDP Tag.jpeg.
- 1.5. **QUESTION** – What is the manufacturer for the fire alarm. **ANSWER** – Fire-Lite is the district standard.

All other provisions of the Contract Documents shall remain unchanged. This addendum is hereby made a part of the Contract Documents to the same extent as those provisions contained in the original documents and all itemized listings thereof.

Attachment MDP Tag.jpeg



End of Addendum